
Gira Alarm Connect security system

Firmware version: 2.0.246

Date: 01/02/2021

Gira Project Assistant (GPA) version: 4.5 or higher

We recommend that you always use the latest available GPA version.

New functions

- New wireless smoke alarm device (Order No.: 5236 16) for the Alarm Connect security system
- A fire alarm is issued to the security guard irrespective of the activation status

Errors rectified

- Connection to security guard:
 - Customer number was transmitted incorrectly via SIA protocol
 - Routine call CID transmitted the incorrect event key